

Sponsor: Johan Bosman Nanotex Group s.r.o. Podkrusnohorska 271 Litvinov-Chudein, 43603 CZECH REPUBLIC

Viral Filtration Efficiency (VFE) Final Report

Test Article: FMPV2020L

SAMPLE NO: V1 SAMPLE NO: V2 SAMPLE NO: V3 SAMPLE NO: V4 SAMPLE NO: V5

Purchase Order: Study Number:

NGPO 0182020 1274107-S01

Study Received Date:

05 Mar 2020

Testing Facility: Nelson Laboratories, LLC 6280 S. Redwood Rd.

Test Procedure(s):

Salt Lake City, UT 84123 U.S.A.

Standard Test Protocol (STP) Number: STP0007 Rev 16

Deviation(s): None

Summary: The VFE test is performed to determine the filtration efficiency of test articles by comparing the viral control counts upstream of the test article to the counts downstream. A suspension of bacteriophage ФX174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at 1.1 - 3.3 x 103 plaque forming units (PFU) with a mean particle size (MPS) of 3.0 µm ± 0.3 µm. The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. The VFE test procedure was adapted from ASTM F2101.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Sponsor Labeled Side

Test Area: ~40 cm²

VFE Flow Rate: 28.3 Liters per minute (L/min)

Conditioning Parameters: 85 ± 5% relative humidity (RH) and 21 ± 5°C for a minimum of 4 hours

Positive Control Average: 1.9 x 10³ PFU Negative Monitor Count: <1 PFU

MPS: 3.2 µm

Study Directo

801-290-7500

Study Completion Date

1274107-S01

nelsonlabs.com

sales@nelsonlabs.com

FRT0007-0001 Rev 16

Page 1 of 2



Results:

| Test Article Number | Percent VFE (%) |
|---------------------|--------------------|
| V1 | 99.8 |
| V2 | >99.9 ^a |
| V3 | 99.9 |
| V4 | 99.7 |
| V5 | 99.8 |

^a There were no detected plaques on any of the Andersen sampler plates for this test article.

The filtration efficiency percentages were calculated using the following equation:

$$\% VFE = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article Note: The plate count total is available upon request